

November 25, 2009

Mr. Mike Elabarger
County of Loudoun
Department of Planning MSC#62
1 Harrison Street, S.E.
P.O. Box 7000
Leesburg, Virginia 20177-7000

Re: CWS Exit 5 Site Claiborne Parkway
Loudoun County Application Number SPEX 2009-0030 and CMPT 2009-0009

Dear Mr. Elabarger:

We have reviewed the above application as requested in your November 4, 2009 transmittal. We offer the following comments:

1. The driveway should be perpendicular to the ramp.
2. The entrance should conform to VDOT standard PE-1.
3. The entrance should be paved for at least 25' from the edge of the ramp pavement.

If you have any questions, please call me at (703) 383-2424.

Sincerely,

Thomas B. VanPoole, P.E.
Senior Transportation Engineer

bcc: Imad Salous, P.E.